



DRG No.

- WIRING & CABLES:
- MAINS: 2x 10mm² PVC SWLS
 - GENERATOR: 2x 10mm² PVC SWLS
 - BUS BAR RISER: 2x 10mm² PVC SWLS
 - BASEMENT DIS. BOARD: 2x 10mm² PVC SWLS
 - CA - A/C UNIT: 2x 16mm² PVC SWLS
 - CB - A/C UNIT: 2x 16mm² PVC SWLS
 - CE - DRY COOLER: 2x 16mm² PVC SWLS
 - FUEL TRANSFER: 2x 25mm² PVC SWLS
 - GEN. AUX.: 2x 4mm² PVC SWLS

No	DESCRIPTION	CHK'D	APP'D	DATE
2	TC TIMER ADDED & FUEL TRANSFER WITH SWJ	JK	DRC	23.11.11
1	F10/F11/F12/F13 FUSES CHANGED TO 10A - HRC	JLK	LS	14.11.11

MEDWAY ELECTRICAL & MECHANICAL SERVICES
 "Generator Specialists"
 MEDWAY HOUSE
 JILLINGHAM ROAD
 JILLINGHAM
 KENT

CREDIT AGRICOLE
 CHANGE OVER & DISTRIBUTION PANEL

DRAWN	TRACED	CHECKED	APPROVED	DATE	SCALE
SBK	/	DRC	LS	25.7.11.	/

DRAWING No. **E750/9591/A3**