
PROCEDURE

Type EMERGENCY

Description

1.2 ELECTRICAL SUPPLY FAILURE

This describes the general actions to take in the event of a mains supply failure and when the supply is resumed.

Notes

1. Fault finding and repairs on electrical installation should only be carried out by a fully qualified electrician.
2. The main incoming supply has been provided by the London Electricity Board, and is not covered within this manual.

In case of Supply failure, please contact the LEB on:

During Office Hours 071 251 5262
Out of Office Hours
plus Bank Holidays 071 733 1930

In case of Emergency, please contact the LEB on 071 251 5161

Step	Action	Notes
1	Check whether the failure is 'local' or general.	Check whether local lighting power or ancillary circuits, or the complete installation is affected.
2	If the failure is local, Check miniature circuit breaker or fuse in appropriate distribution board and reinstate to 'on' position after the circuit has been checked for faults using standard procedures.	
3	If the failure is more general, the appropriate outgoing switch fuse on the L.V. switchgear should be checked to ascertain whether it has been blown.	
4	If there is a complete failure, check if the main circuit breaker on the main incoming supply has tripped.	